

ARCADIA PWS
 Public Water System ID Number: MO4010023
2025 Annual Water Quality Report
(Consumer Confidence Report)
Optional Monitoring (not required by EPA)
Optional Contaminants

Monitoring is not required for optional contaminants.

Secondary Contaminants	Collection Date	Your Water System Highest Sampled Result	Range of Sampled Result(s) (low - high)	Unit	SMCL
ALKALINITY, CaCO3 STABILITY	7/16/2024	257	257	MG/L	
ALUMINUM	7/16/2024	0.0184	0.0184	MG/L	0.05
CALCIUM	7/16/2024	51.9	51.9	MG/L	
CHLORIDE	7/16/2024	11.5	11.5	MG/L	250
HARDNESS, CARBONATE	7/16/2024	251	251	MG/L	
IRON	7/16/2024	0.0166	0.0166	MG/L	0.3
MAGNESIUM	7/16/2024	29.6	29.6	MG/L	
MANGANESE	7/16/2024	0.0388	0.0388	MG/L	0.05
NICKEL	7/16/2024	0.00157	0.00157	MG/L	0.1
PH	7/16/2024	7.73	7.73	PH	8.5
POTASSIUM	7/16/2024	1.73	1.73	MG/L	
SODIUM	7/16/2024	9.4	9.4	MG/L	
SULFATE	7/16/2024	18.4	18.4	MG/L	250
TDS	7/16/2024	262	262	MG/L	500
ZINC	7/16/2024	0.0027	0.0027	MG/L	5

Secondary standards are non-enforceable guidelines for contaminants that may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste, odor or color) in drinking water. EPA recommends these standards but does not require water systems to comply.